



1 **EU-TYPE EXAMINATION CERTIFICATE**

2 Component intended for use in Potentially Explosive Atmospheres Directive 2014/34/EU

3 Certificate Number: **Sira 01ATEX3016U** Issue: **11**

4 Component: **Type B Lead Acid Motive Power Cells**

5 Applicant: **Energys S.A.R.L.**

6 Address: ZI Est
Rue Alexander Fleming
62033 Arras
France

7 This component and any acceptable variation thereto is specified in the schedule to this certificate and the documents therein referred to.

8 CSA Group Netherlands B.V., Notified Body Number 2813 in accordance with Articles 17 and 21 of Directive 2014/34/EU of the European Parliament and of the Council, dated 26 February 2014, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of a component intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in the confidential reports listed in Section 14.2.

9 Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule to this certificate, has been assured by compliance with the following documents:

EN 60079-0:2006 EN 60079-7:2007 EN 61241-0:2006 EN 61241-1:2004

10 The sign 'U' is placed after the certificate number to indicate that the product assessed is a component and may be subject to further assessment when incorporated into equipment. Any limitations of use are listed in the schedule to this certificate.

11 This EU-Type Examination Certificate relates only to the design and construction of the specified component. If applicable, further requirements of this Directive apply to the manufacture and supply of this component.

12 The marking of the component shall include the following:



II 2 G
II 2 D
Ex e II
Ex tD A21 IP65 (This marking is applicable but does not appear on the actual cells, however, it is applied to the batteries that they subsequently form part of.)



I M2
Ex e I

Project Number 2840

Signed:

Title: Director of Operations

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 01ATEX3016U
Issue 11

13 DESCRIPTION OF COMPONENT

The Type B range of lead acid traction cells are designated by the manufacturer as IEC 254-2 Series E cells. Each cell is 158 mm wide and has 2 to 12 positive plates terminated on two or four terminal posts. Connection to the terminal posts may be by the use one of the following methods:

- Sealed post terminals, welded, with insulating covers.
- Induction welded terminals with encapsulated caps.
- Female threaded inserts with insulated bolt heads.
- Female threaded inserts incorporating insulated caps.
- Male threaded inserts with insulated anti-vibration locknuts.
- An alternative solid link cell connector for those batteries where no movement of the cell is possible after installation.
- An alternative cell connector where the end of the connecting cable is welded to a copper strip to form a termination, which is then fastened to the cell terminal post by a threaded fastener.

Vent plugs are fitted to the top of the cell casing and may be a flip-top type or a type having an indicator/float arrangement. The cell is topped up in a non-hazardous area. An air mixing tube is also provided for use during charging of the cell, which is also an operation carried out in a non-hazardous area.

Typical European cell type designation: SPzB42
S = (S)ingle or (D)ouble posted cells
PzB42 = Type

Typical Hawker Traction cell type designation: SOTHE5
S = (S)ingle or (D)ouble posted cells
OTHE = Type
5 = Number of positive plates

Correlation of cell types	
European	Hawker Traction
PzB23	Not applicable
PzB32	CBH
PzB42	OTHE
PzB55	EXHE
PzB65	XHE
PzB75	BRHE
PzB85	PEG
PzB100	ETE
PzB105	TEHE



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 01ATEX3016U
Issue 11

Variation 1 (dated 15 October 2002) - This variation introduced the following changes:

- i. The correlation of cell types was modified and a new cell type, CBH, was included in the list.
- ii. The cell height to be changed.

Variation 2 (dated 3 April 2003) - This variation introduced the following changes:

- i. The recognition of changes to IEC cell type designations.
- ii. The introduction of an alternative solid link cell connector for those batteries where no movement of the cell is possible after installation.
- iii. The introduction of an alternative cell connector where the end of the connecting cable is welded to a copper strip to form a termination, which is then fastened to the cell terminal post by a threaded fastener.
- iv. The introduction of Apparatus Group I, Category M2 and EEx e I marking.

Variation 1 (dated 14 October 2005) - This variation introduced the following changes:

- i. The manufacturer's name was changed from Hawker France S.A. to Hawker S.A.R.L.
- ii. The introduction of minor modifications to the certified drawings, none of which affect aspects of the product that are relevant to explosion safety.

Variation 2 (dated 11 August 2006, re-issued 19 September 2006) - This variation introduced the following changes:

- i. The use of 2.4 mm thick negative cell plates with alternative separator thickness.
- ii. The cell enclosures to be manufactured with a larger wall section tolerance.

Variation 3 (dated 6 August 2007) - This variation introduced the following changes:

- i. Following appropriate re-assessment to demonstrate compliance with the requirements of the EN 60079 series of standards, the documents originally listed in section 9, EN 50014:1997 (amendments A1 to A2), EN 50019:2000 and EN 50281-1-1:1998, were replaced by EN 60079-0:2006, EN 60079-7:2007, EN 61241-0:2006 and EN 61241-1:2004, the markings in section 12 were updated accordingly.
- ii. Minor modifications of the certified drawings were recognised, these are amendments in-line with the new standards listed above and also correct typographical errors.
- iii. The use of battery arrangements up to 400 V was permitted.
- iv. An additional warning label was introduced; this uses an alternative label material and fixing method.
- v. The correlation of cell types was modified and a new cell type, PzB23, was included in the list.

Variation 4 (dated 26 September 2007) - This variation introduced the following change:

- i. The addition of two alternative materials for cell enclosure.



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 01ATEX3016U
Issue 11

Variation 5 - This variation introduced the following changes:

- i. To allow the introduction of an alternative polypropylene copolymer housing material.
- ii. The recognition of minor drawing modifications; these amendments are administrative or involve changes to the design that do not affect the aspects of the product that are relevant to explosion safety.
- iii. To recognise a rise in the maximum discharge current from 270 A to 310 A.
- iv. The PzB 95 and PzB 100, listed in the Correlation of cell types table, were corrected to read PzB 100 and PzB 105 respectively.
- v. Drawings SIRAATEX1, SIRAATEX4 P25127 and P25128 are amended to remove reference to the minimum contact area.
- vi. Drawings SIRAATEX1, SIRAATEX4 P25127, P25128, P24807 and P24808 have been modified to include a wider range of cable cross sections.

14 DESCRIPTIVE DOCUMENTS

14.1 Drawings

Refer to Certificate Annexe.

14.2 Associated Sira Reports and Certificate History

Issue	Date	Report no.	Comment
0	1 November 2001	R53A7212B	The release of the prime certificate in the name of Hawker GmbH, Dieckstrasse 42, D-58089 Hagen, Germany.
1	15 October 2002	R53A9083A	The introduction of Variation 1.
2	3 April 2003	R53A9706B	The introduction of Variation 2.
3	6 July 2004	R53A11442A	The re-issue of the prime certificate in the name of Hawker France SA, ZI Est, Rue Alexander Fleming, 62033 Arras, France to introduce the changes described in report number R53A11442A and to incorporate variation 1 dated 15 October 2002 and variation 2 dated 3 April 2003.
4	14 October 2005	R51A13711A	The introduction of Variation 1.
5	11 August 2006	R51A15249B	The introduction of Variation 2, subsequently re-issued on 19 September 2006 to permit report number R51A15249B to replace report number R51A15249A.
6	6 August 2007	R51A16168A	This Issue covers the following changes: <ul style="list-style-type: none">• All previously issued certification was rationalised into a single certificate, Issue 6, Issues 0 to 5 referenced above are only intended to reflect the history of the previous certification and have not been issued as documents in this format.• The introduction of Variation 3.
7	26 September 2007	R51A17275A	The introduction of Variation 4.
8	14 February 2008	R52A17587A	To recognise the change of Applicant's name from Hawker S.A.R.L. To Enersys S.A.R.L.
9	11 February 2010	R19846A/00	The introduction of Variation 5.
10	29 March 2011	R51A16168A/01	Re-issued to allow Report R51A16168A/01 to replace R51A16168A

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem Netherlands



SCHEDULE

EU-TYPE EXAMINATION CERTIFICATE

Sira 01ATEX3016U
Issue 11

11	15th October 2019	2840	<ul style="list-style-type: none">• Transfer of certificate Sira 01ATEX3016U from Sira Certification Service to CSA Group Netherlands B.V..• EC Type-Examination Certificate in accordance with 94/9/EC updated to EU Type-Examination Certificate in accordance with Directive 2014/34/EU. <i>(In accordance with Article 41 of Directive 2014/34/EU, EC Type-Examination Certificates referring to 94/9/EC that were in existence prior to the date of application of 2014/34/EU (20 April 2016) may be referenced as if they were issued in accordance with Directive 2014/34/EU. Variations to such EC Type-Examination Certificates may continue to bear the original certificate number issued prior to 20 April 2016.)</i>
----	-------------------	------	---

15 SPECIAL CONDITIONS FOR SAFE USE

15.1 These components comply with EN 60079-0:2006 clause 23.2 (acceptable electrochemical systems), EN 60079-7:2007 clauses, 5.7.3 (classification), 5.7.1.3 (cells), 5.7.1.4 (connections) and 6.6.3 (shock test). When they are assembled into a battery, the remaining clauses of EN 60079-7:2007 need to be addressed with particular reference to clauses 5.7.1 (general requirements), 5.7.4 (charging in hazardous areas), 5.7.5 (discharge of cells), 5.7.6 (incorporation of other protection concepts), 5.7.7 (disconnection and transportation), 5.7.1.2 (battery containers), 6.6.2 (insulation resistance) and 6.6.4 (ventilation).

16 ESSENTIAL HEALTH AND SAFETY REQUIREMENTS OF ANNEX II (EHSRs)

The relevant EHSRs that are not addressed by the standards listed in this certificate have been identified and individually assessed in the reports listed in Section 14.2.

Certificate Annexe



Certificate Number: Sira 01ATEX3016U
Component: Type B Lead Acid Motive Power Cells
Applicant: Enersys S.A.R.L.

Issue 0 to 2

The drawings associated with these Issues were replaced by those listed in Issue 3.

Issue 3

Number	Sheet	Rev.	Date	Description
SIRAATEX1	1 of 1	4	28 May 04	158 mm Type B Lead Acid Motive Power Cells
P25326	1 of 4	2	28 May 04	'France' Manufactured Parts Labels
P25326	2 of 4	2	28 May 04	'Germany' Manufactured Parts Labels
P25326	3 of 4	2	28 May 04	'Poland' Manufactured Parts Labels
P25326	4 of 4	2	28 May 04	'Czech Republic' Manufactured Parts Labels

Issue 4

Number	Sheet	Rev.	Date	Description
SIRAATEX1	1 of 1	5	27 Jun 05	158 mm Type B Lead Acid Motive Power Cells
P25326	1 of 4	3	27 Jun 05	'France' Manufactured Parts Labels
P25326	2 of 4	3	27 Jun 05	'Germany' Manufactured Parts Labels
P25326	3 of 4	3	27 Jun 05	'Poland' Manufactured Parts Labels
P25326	4 of 4	3	27 Jun 05	'Czech Republic' Manufactured Parts Labels

Issue 5

Number	Sheet	Rev.	Date (Sira stamp)	Description
SIRAATEX1	1 of 1	7	11 Sep 06	158 mm Type B Lead Acid Motive Power Cells

Issue 6

Number	Sheet	Rev.	Date (Sira stamp)	Description
SIRAATEX1	1 of 1	9	25 Jul 07	Acid Motive Power Cells Type B
P25326	1 of 4	5	25 Jul 07	Cell/Battery Labels
P25326	2 of 4	5	25 Jul 07	Cell/Battery Labels
P25326	3 of 4	6	25 Jul 07	Cell/Battery Labels
P25326	4 of 4	5	25 Jul 07	Cell/Battery Labels

Issue 7

Number	Sheet	Rev.	Date (Sira stamp)	Description
SIRAATEX1	1 of 1	10	26 Sept 07	Acid Motive Power Cells Type B

Issue 8

Number	Sheet	Rev.	Date (Sira stamp)	Description
SIRAATEX1	1 of 1	13	14 Feb 08	Acid Motive Power Cells Type B

Issue 9

Number	Sheets	Rev.	Date (Sira stamp)	Description
SIRAATEX1	1 of 1	15	18 Jan 10	Acid Motive Power Cells Type B
P25326	1 of 4	7	18 Jan 10	'France' Manufactured Parts Labels

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands

Certificate Annexe



Certificate Number: Sira 01ATEX3016U

Component: Type B Lead Acid Motive Power Cells

Applicant: Enersys S.A.R.L.

Number	Sheets	Rev.	Date (Sira stamp)	Description
P25326	2 of 4	7	18 Jan 10	'Germany' Manufactured Parts Labels
P25326	3 of 4	8	18 Jan 10	'Poland' Manufactured Parts Labels
P25326	4 of 4	7	18 Jan 10	'Czech Republic' Manufactured Parts Labels

Issue 10 No new drawings were introduced.

This certificate and its schedules may only be reproduced in its entirety and without change

CSA Group Netherlands B.V.
Utrechtseweg 310,
6812 AR, Arnhem,
Netherlands